

HOME INSPECTIONS
 677 [REDACTED] CT
 19958

Test Address:

129 [REDACTED]
 19958

Email: wld [REDACTED] yahoo.com
 Phone: [REDACTED]

Sample Date: January 7, 2013
 Date Received: January 8, 2013
 Analysis Date: January 9, 2013
 Report Date: January 10, 2013
 Sample Location:

Test / COC #: 6 [REDACTED]
 Sample ID: 01 [REDACTED] 3-02 [REDACTED]

CERTIFICATE OF WATER ANALYSIS


TEST ITEM	RESULT	ACCEPTABLE RANGE	DETERMINATION
COLIFORM BACTERIA	PRESENT		Pass
E. COLI	ABSENT		Pass
LEAD	0 ppb	0 to 14.9 ppb	Pass
NITRATES (AS MEASURED AS NITROGEN)	8.29 mg/L	0 to 9.9 mg/L	Pass
NITRITES (AS MEASURED AS NITROGEN)	0 mg/L	0 to 1.0 mg/L	Pass

BDL = Below detection limit; cfu = colony forming units; mg/L = milligrams per liter; ntu = nephelometric turbidity units
 pH = acidity/alkalinity units; ppm = parts per million; ppb = parts per billion; μ S/cm = microSiemens per centimeter

CONCLUSION: PASS

All of the tested parameters meet the Environmental Protection Agency's (EPA) Primary (health-related) Drinking Water Standards maximum contaminant level goals for human consumption, as well as the FHA/HUD general established statutes for maximum contaminant levels for water potability.

The EPA is responsible for the National Primary Drinking Water Regulations, which are health-related standards that establish the Maximum Contaminant Levels. MCLs are the maximum permissible level of a contaminant in water delivered to users of a public water system. MCLs are enforceable under the Safe Drinking Water Act. National Primary Drinking Water Regulations can be found on the web at: <http://water.epa.gov/drink/contaminants/index.cfm>



John D. Shane Ph.D., QA / Technical Manager